


BROWERS J.C. No.	
SWERS STOCKING	
OUTPUT	1250 kVA
VOLTAGE RATIO	11000 / 433
AMPERES	65.67 / 1667
PHASES	3
Frequency	50Hz
VECTOR SYMBOL	Dyn11

ESTIMATED WEIGHTS	KG
CORE AND WINDINGS	1808
COOLING LIQUID	743 LTRS
TOTAL WEIGHT	3410

 BM TRADA certification body  UKAS certification body 012		This drawing is COPYRIGHT and the property of Bowers Electricals Ltd. It must not be copied (in whole or in part) without prior written consent of the company. ©	
TOLERANCE UNLESS OTHERWISE STATED: ± 5mm FOR DIMENSIONS UP TO 250mm; ± 10mm FOR DIMENSIONS UP TO 1000mm; ± 20mm FOR DIMENSIONS OVER 2000mm.			
RevNo			
Revision note			
Date	Signed	Ctd.	
 Bowers Electricals Ltd Heaton Gate Road, Heaton, Derbyshire, DE73 7DY T: 01332 772 76171 E-mail: enquiries@bowerselectricals.co.uk Drawn by A.WILCOXSON Checked by C.MEASE Approved by D.MESBURY Date 11/10/17 Dwg Size A2			
GENERAL ARRANGEMENT OF 1250kVA ONAN TRANSFORMER DRG No. BE5482  FIRST ANGLE Scale 1:20 Revision 0 Sheet 1/1			