



ITEM	DESCRIPTION
1	HV CABLE BOX 3 POLE 1 GLAND (TERMINATION KIT REQD)
2	LV CABLE BOX 4 POLE 11 GLAND AIR FILED
3	TRANSFORMER LIQUID FILER COVER PLATE
4	THERMOMETER POCKET
5	LIQUID LEVEL GAUGE
6	JACKING ANGLES
7	EARTHING TERMINAL
8	SKID UNDERBASE C/W HAULAGE HOLES
9	MAIN FILTERS
10	SILICA GEL BREATHER (SUPPLIED LOOSE)
11	TAPPING SELECTOR CONTROL HANDLE
12	RATING AND DIAGRAM PLATE
13	DRAIN VALVE
14	RADIATORS

OUTPUT	1500 KVA
VOLTAGE RATIO	11000 / 433
AMPERES	78.73 / 2000
PHASES	3
FREQUENCY	50Hz
VECTOR SYMBOL	Dyn11
ESTIMATED WEIGHTS	
CORE AND WINDINGS	KG 1902
COOLING LIQUID	882 LTRS 755
TOTAL WEIGHT	3765

PAINT FINISH:- DARK ADMIRALTY GREY (BS381c 632)



BM TRADA

CERTIFICATION

UKAS

QUALITY MANAGEMENT

012

ISO 9001:2008

Rev

1

Revision note

12/10/11

AW

CM

12/10/11

AW

CM

12/10/11

AW

CM

Bowers

Electricals Ltd

Heanor Gate Road,

Heanor, Derbyshire, DE75 7GX

Tel: 01773 531531 Fax: 01773 716171

E-mail: enquiries@bowerselec.co.uk

Drawn by

A.WILCOXSON

Checked by

C.MEENE

Approved by

D.MESBITT

Orig. Job No.

TR61055/86

Date

18/10/10

Dwg. Size

A3

GENERAL ARRANGEMENT

OF 1500KVA ONAN

TRANSFORMER

DRG No. BE5193

Scale

1:20

Revision

1

Sheet

1/1

This drawing is COPYRIGHT and the property of Bowers Electricals Ltd. It must not be copied, in whole or in part, without prior written consent of the company.

TOLERANCE UNLESS OTHERWISE STATED:
3.0mm FOR DIMENSIONS UP TO 250mm
5.0mm FOR DIMENSIONS OVER 250mm
±.20mm FOR DIMENSIONS OVER 2000mm.