



ITEM	DESCRIPTION
1	HV CABLE BOX 3 POLE 7 GLAND (TERMINATION KIT RECD)
2	LV CABLE BOX 4 POLE 4 GLAND AIR FILLED
3	TRANSFORMER OIL FILLER COVER PLATE
4	THERMOMETER POCKET
5	LIQUID LEVEL GAUGE
6	JACKING PLATFORMS
7	EARTHING TERMINAL
8	SKID UNDERBASE CW HAULAGE HOLES
9	MAIN LIFTERS
10	BREATHER PIPE CW BREATHER
11	TAPPING SELECTOR CONTROL HANDLE
12	RATING AND DIAGRAM PLATE
13	DRAIN VALVE
14	RADIATORS

BOWERS JOB No.	ESTIMATED WEIGHTS
BOWERS STOCK No.	KG
VOLTAES RATIO	CORE AND WINDINGS
PHASES	COOLANT LIQUID
FREQUENCY	599 LTRS
VECTOR SYMBOL	2257

BOWERS JOB No.	ESTIMATED WEIGHTS
BOWERS STOCK No.	KG
VOLTAES RATIO	CORE AND WINDINGS
PHASES	COOLANT LIQUID
FREQUENCY	599 LTRS
VECTOR SYMBOL	2257

ISO 9001 : 2008

This drawing is COPYRIGHT and the property of Bowers Electrical Ltd. It must not be copied (in whole or in part) without prior written consent of the company.

TOLERANCE UNLESS OTHERWISE STATED:  
 ± 0.5mm FOR DIMENSIONS UP TO 250mm  
 ± 1.0mm FOR DIMENSIONS UP TO 1000mm  
 ± 2.0mm FOR DIMENSIONS OVER 1000mm.

Drawn by  
A.W.H. COXSON

Checked by  
C.MEENSE

Approved by  
G.MENSBITT

Orig. Job No.  
28030174

Date  
28/03/14

Dwg. Size  
A2

**Bowers** Electrical Ltd

Header Gate Road, DRYTS TQX  
 Tel: 01773 531531 Fax: 01773 716171  
 Email: enquiries@bowerselec.co.uk

GENERAL ARRANGEMENT OF  
BOWERS STANDARD 500KVA  
LOW LOSS KXAN  
TRANSFORMER

DRG No. **BE5296**

FIRST ANGLE

Scale  
1:20

Revision  
0

Sheet  
1/1